

Certificate of Compliance

Certificate: 1945462 (LR 115116) **Master Contract:** 190896

Project: 2174799 **Date Issued:** 2009/05/13

Issued to: Bimed Teknik Aletler Sanayi Ve

Ticaret A.S.

Bevlikduzu Mevkii

S.S. Bakir Ve Pirinc Sanayi Sitesi Leylak Cad. No. 15, Buyukcekmece

Istanbul, **Turkey**

Attention: Viktor Birmizrahi

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by:

Nick Sajatovich

Authorized by: Nick Alfano, Operations

Manager

PRODUCTS

CLASS 4412 81 - OUTLET BOXES AND FITTINGS - Bushings, Fittings - Certified to US

Standards

CLASS 4412 01 - OUTLET BOXES AND FITTINGS - Bushings, Fittings

Non-metallic cord connectors, Series 180, 181, 182, 183, BS, BM, BI and BN, liquid-tight, in NPT, PG and

DQD 507 Rev. 2004-06-30



Certificate: 1945462 (LR 115116) **Master Contract:** 190896

Project: 2174799 **Date Issued:** 2009/05/13

metric threads, with or without locknuts and intended for use in non-hazardous indoor locations.

Notes:

- 1. These connectors are Certified as components and intended to be used in electrical equipment, where the suitability is determined in the end use application.
- 2. These connectors are Certified only for use with the applicable cord ranges and manufacturer's recommended torque.
- 3.Suffixes may be added to designate thread size. "Suffix X represents the connectors assembled with locknuts". "Code BMX designates the PG connectors with locknuts". "Code BMMX designates the Metric connectors with locknuts". "Code including (P) designates the connectors assembled with dust plugs".
- 4. These connectors are available in black (RAL9005), dark grey (RAL7001), light grey (RAL 7035) (RAL 9003) White; (RAL 3020) Red; and (RAL 5015) Blue color.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 18.3 - Conduit, Tubing and Cable Fittings.

ANSI/UL 514B - Conduit, Tubing and Cable Fittings.